



CERTIFICATE OF APPROVAL

No CF 807

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

FALCON PANEL PRODUCTS LTD

Clock House, Station Approach, Shepperton
Middlesex, TW17 8AN

Tel: 01932 256580 Fax: 01932 230268

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT
Falcon Panel Products Ltd
FD30 Strebord 44
ITT Timber Door Blanks

TECHNICAL SCHEDULE
TS10 Fire Resisting Door
Assemblies with Non
Metallic Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 6th January 2011
Revised: 13th January 2022
Valid to: 1st November 2026





CERTIFICATE No CF 807

FALCON PANEL PRODUCTS LTD

Falcon Panel Products Ltd. FD30 Strebord 44 Timber Door Blanks

This approval relates to the use of the above doors in providing fire resistance of 30 minutes insulation (if incorporating not more than 20% of uninsulating glass) and 30 minutes integrity as defined in BS 476: Part 22. Subject to the undermentioned conditions, the doors would be expected to meet the relevant requirements of BS 9999 for FD30 door assemblies when used in accordance with the provisions therein.

1. This certification is provided to the client for their own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
2. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - iii) Inspection and surveillance of factory production control
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing in accordance with TS10
3. The door blanks comprise cellulosic cored leaves in various finishes for use with timber frames, with intumescent edge seals (ITT FD30).
4. This approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door.
5. This approval is applicable to latched and unlatched, single-acting, single and double-leaf, ITT assemblies, at leaf dimensions up to those given in Tables 1, 2, 3 and 4.
6. Glazing shall only be undertaken by the door manufacturer, or a CERTIFIRE approved Licensed Door Processor, and shall be in accordance with the Data information Sheet and Construction Specification. No site cutting or glazing of apertures is permitted.
7. Hardware items, including closing devices and intumescent fire seals, shall be as specified in the data sheet.
8. The door assembly shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes.
9. Labels to the CERTIFIRE design, or approved by CERTIFIRE, referencing CERTIFIRE and CERTIFIRE Ref. No. CF807 and FD30 classifications resistance shall be affixed to each door in the prescribed position.

Page 2 of 4 Signed
C/021, D/009, N/007
& S/009

Issued: 6th January 2011
Revised: 13th January 2022
Valid to: 1st November 2026

CERTIFICATE No CF 807 FALCON PANEL PRODUCTS LTD

Falcon Panel Products Ltd. FD30 Strebord 44 Timber Door Blanks

10. The approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 10 x 4 mm intumescent	2187 (at 902 wide)	938 (at 2102 high)	1.97
Single-Acting, Double-Leaf Latched / Unlatched 10 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2463 (at 902 wide)	1057 (at 2102 high)	2.22
Table 1. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Mann McGowan Pyrostrip 100P Intumescents			

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 10 x 4 mm intumescent	2540 (at 1165 wide)	1165 (at 2540 high)	2.96
Single-Acting, Single-Leaf Latched / Unlatched 15 x 4 mm intumescent	3111 (at 915 wide)	1016 (at 2800 high)	2.85
Single-Acting, Single-Leaf Latched 15 x 4 mm intumescent	2803 (at 1072 wide)	1113 (at 2700 high)	3.00
Single-Acting, Double-Leaf Latched / Unlatched 10 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2600 (at 1152 wide)	1152 (at 2600 high)	3.00
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (Single 15 x 4 mm to meeting edge)	2635 (at 999 wide)	1165 (at 2259 high)	2.63
Table 2. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Lorient Type 617 or 100P Intumescents			

Note: Under no circumstances must the maximum height, maximum width or maximum area be exceeded without separate CERTIFIRE approval.
All timber framed door assembly configurations may incorporate overpanels which include a

Page 3 of 4 Signed
C/021, D/009, N/007
& S/009



Issued: 6th January 2011
Revised: 13th January 2022
Valid to: 1st November 2026

CERTIFICATE No CF 807 FALCON PANEL PRODUCTS LTD

transom rail as detailed within data sheet

Falcon Panel Products Ltd. FD30 Strebord 44 Timber Door Blanks

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Double-Leaf Unlatched only 20 x 4 mm intumescent to head, 10 x 4 mm intumescent to jambs, (Single 15 x 4 mm to each meeting edge)	2600 (at 1081 wide)	1150 (at 2440 high)	2.81
Table 3. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Double-Leaf, Unlatched with 12 mm rebated meeting stiles with Lorient Type 617 or 100P Intumescents			

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 15 x 4 mm intumescent	2195 (at 928 wide)	956 (at 2131 high)	2.04
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (Single 15 x 4 mm to meeting edge)	2555 (at 1177 wide)	1177 (at 2555 high)	3.01
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2811 (at 915 wide)	1054 (at 2440 high)	2.57
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (2No. 15 x 4 mm to meeting edge)	2942 (at 1165 wide)	1165 (at 2942 high)	3.43
Table 4. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Pyroplex FO8700 Graphite Rigid box seal Intumescents			

Note: Under no circumstances must the maximum height, maximum width or maximum area be exceeded without separate CERTIFIRE approval

All timber framed door assembly configurations may incorporate overpanels which include a transom rail as detailed within data sheet

Page 4 of 4 Signed
C/021, D/009, N/007
& S/009



Issued: 6th January 2011
Revised: 13th January 2022
Valid to: 1st November 2026

CF 807 DATA SHEET

1. General

This door leaf has been fire tested and is certified by CERTIFIRE as being capable of providing fire resistance of 30 minutes integrity and 30 minutes insulation (if incorporating not more than 20% of uninsulated glass) as defined in BS 476: Part 22: 1987, when installed in accordance with the following conditions. Subject to these, the door will meet the relevant requirements of BS 9999 for FD30 doorsets when used in accordance with the provisions therein.

In recognition of this the leaf carries a prefixed label on the top edge or hanging edge of the door, issued under the terms of the CERTIFIRE scheme. This label uniquely identifies the door leaf, the manufacture of which complies with a CERTIFIRE approved Quality management System and is subject to on-going surveillance. This label must not be removed.

It is emphasised that the certification is conditional upon the following instructions being complied with in their entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door. Door assemblies supplied pre-fitted with components by the Prime Door Manufacturer / Licensed Door Processor may be considered to meet the requirements in respect of those items.

2. Door Leaf

This approval is applicable to single-action, single and double-leaf, latched and unlatched, assemblies at leaf dimensions up to those detailed within tables 1, 2, 3 and 4 below.

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 10 x 4 mm intumescent	2187 (at 902 wide)	938 (at 2102 high)	1.97
Single-Acting, Double-Leaf Latched / Unlatched 10 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2463 (at 902 wide)	1057 (at 2102 high)	2.22
Table 1. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Mann McGowan Pyrostrip 100P Intumescents			

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 10 x 4 mm intumescent	2540 (at 1165 wide)	1165 (at 2540 high)	2.96
Single-Acting, Single-Leaf Latched / Unlatched 15 x 4 mm intumescent	3111 (at 915 wide)	1016 (at 2800 high)	2.85
Single-Acting, Single-Leaf Latched Only 15 x 4 mm intumescent	2803 (at 1072 wide)	1113 (at 2700 high)	3.00
Single-Acting, Double-Leaf Latched / Unlatched 10 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2600 (at 1152 wide)	1152 (at 2600 high)	3.00
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (Single 15 x 4 mm to meeting edge)	2635 (at 999 wide)	1165 (at 2259 high)	2.63
Table 2. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Lorient Type 617 or 100P Intumescents			

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Double-Leaf Unlatched only 20 x 4 mm intumescent to head, 10 x 4 mm intumescent to jambs, (Single 15 x 4 mm to each meeting edge)	2600 (at 1081 wide)	1150 (at 2440 high)	2.81
Table 3. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Double-Leaf, Unlatched with 12 mm rebated meeting stiles with Lorient Type 617 or 100P Intumescents			

Door assembly configuration	Max. Height (mm)	Max. Width (mm)	Area (m ²)
Single-Acting, Single-Leaf Latched / Unlatched 15 x 4 mm intumescent	2195 (at 928 wide)	956 (at 2131 high)	2.04
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (Single 15 x 4 mm to meeting edge)	2555 (at 1177 wide)	1177 (at 2555 high)	3.01
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (2No. 10 x 4 mm to meeting edge)	2811 (at 915 wide)	1054 (at 2440 high)	2.57
Single-Acting, Double-Leaf Latched / Unlatched 15 x 4 mm intumescent (2No. 15 x 4 mm to meeting edge)	2942 (at 1165 wide)	1165 (at 2942 high)	3.43
Table 4. Maximum Permitted Door Leaf Dimensions for Fire Performance Single-Acting, Single and Double-Leaf, Latched and Unlatched with Pyroplex FO8700 Graphite Rigid box seal Intumescents			

Note: Under no circumstances must the maximum height, maximum width or maximum area be exceeded without separate CERTIFIRE approval

All timber framed door assembly configurations may incorporate overpanels which include a transom rail as detailed within data sheet

3. Door Frames

To be any of the following: -

Softwood or Hardwood	i) Density:	440 kg/m ³ min.
	ii) Dimensions:	70 mm by 32 mm min.
	iii) Door Stop:	12 mm deep pinned, screwed, or rebated from solid (440 kg/m ³ min) Where the stop is rebated from solid the overall frame thickness must be increased by 12 mm to accommodate the 12 mm rebate depth.
MDF	i) Density:	750 kg/m ³ min.
	ii) Dimensions:	70 mm by 30 mm min.
	iii) Door Stop:	12 mm deep pinned, screwed, or rebated from solid (440 kg/m ³ min) Where the stop is rebated from solid the overall frame thickness must be increased by 12 mm to accommodate the 12 mm rebate depth.
Jointing:	Butt joints, mortice and tenon, mitred or half lapped joints with the head screw fixed to the jambs using two steel screws	
Door to frame gaps:	Not to exceed 4 mm except at threshold where up to 8 mm is permitted and 3.5 mm at the meeting stiles	

4. Overpanels & Sidepanels

Flush overpanels may be included up to a maximum height of 600 mm and shall include 9 mm thick hardwood lippings (minimum) and opposing lipping to the leaf head or a rebated 20 mm thick hardwood lipping with 22 mm wide by 11 mm deep rebate at the bottom edge, with a corresponding 20 mm thick rebated hardwood lipping in the top edge of the leaf. Overpanels shall be lipped on all edges.

Overpanels to be fixed using steel screws at a maximum of 400 mm centres and a maximum 100 mm from each corner, through the centre of the panel to a depth of at least 30mm.

Door to overpanel meeting edges shall incorporate a 15 mm by 4 mm Lorient intumescent seal in each rebate, or centrally within the leaf / overpanel thickness where a square (non-rebated) door to overpanel meeting edge is adopted.

Where rebated door to overpanel meeting edges are not incorporated on double-leaf assemblies, timber astragals (min 640 kg/m³) are required at the junction between the bottom of the overpanel and the top edge of the door.

Transomed overpanels may be included up to 1000 mm high, with a minimum 40 mm wide transom rail.

Transomed sidepanels may be included up to 1000 mm wide, with a minimum 40 mm wide mullion rail.

5. Glazed Fanlights & Sidelights

Any CERTIFIRE approved glazing systems may be used providing the specification and installation details given in the appropriate certification documents are adhered to.

6. Supporting Construction

The door assemblies are approved to be installed in brick, block, masonry, timber or steel stud supporting constructions of minimum overall thickness 70mm, providing at least 30 minutes fire resistance and previously proven capable of supporting a fire door assembly for the required integrity performance.

Where stud partitions are used these should be suitably constructed to provide a secure fixing for the door assemblies as recommended by the partition manufacturer

7. Installation

The opening may be lined with softwood or hardwood which shall be continuous and of minimum width, 70 mm. Each door frame jamb to be fixed through to the wall at not less than four points with steel or nylon frame fixings screwed and plugged at maximum 600mm centres and penetrating the wall to at least 50 mm. Architrave is optional with no restrictions on material, size or fixing.

Door assemblies shall be installed as stated in BS 8214. Suitable CERTIFIRE approved lineal gap sealing systems may also be utilised to protect the frame / supporting construction gap, subject to the conditions contained within the relevant certificate.

The use of third party accredited installers provides a means of ensuring that installations have been conducted by knowledgeable contractors, to appropriate standards, thereby increasing the reliability of the anticipated performance in fire.

Door leaves may be trimmed to fit the frame by the following maximum amounts:

- Stiles (each) 3 mm
- Top 3 mm
- Bottom No limit providing bottom lippings are not fitted, 3 mm if bottom lipping is fitted.

Note that the maximum door to frame and door to threshold gaps specified shall not be exceeded nor shall the door edge fitted with the CERTIFIRE label be trimmed since removal of the label will invalidate the certification.

The labelled edge may be subjected to minor 'shooting-in', providing the label is not damaged or removed in the process, and the amount of material removed does not exceed that stated previously.

8. Lippings

Hardwood	i) Density:	640 kg/m ³ minimum
	ii) Thickness:	Minimum 5 mm Maximum 25 mm
	iii) Adhesive:	Urea Formaldehyde, Cascamite, PVA or PU
Notes:	All doors, must be lipped to the vertical edges as a minimum with the option to apply lippings to the top and bottom leaf edges,	
	Maximum 2 mm thick decorative PVC / laminate edgings may be applied to the vertical door edges in addition to 5 mm hardwood lippings.	

9. Glazed Apertures

All apertures to be factory prepared by a CERTIFIRE approved Licensed Door Processor. No site cutting of apertures permitted as this will invalidate the certification.

The leaf / leaves may incorporate any CERTIFIRE approved glazing system subject to the conditions contained within the relevant certificate (e.g., maximum size associated with glass or system, edge cover, aperture lining requirements etc.), and the maximum pane dimensions given above (whichever is the smaller):

Aperture dimensions: Doors may incorporate one of more vision panels to the maximum sizes identified in the table below:

Area: Maximum total glazed area of 1.51 m² per leaf

Margins: 100 mm from the perimeter edge, 100 mm between apertures

Maximum Permitted Aperture Dimension		
Max. Height (mm)	Max. Width (mm)	Max. Area (m ²)
2085 (at 725 wide)	822 (at 1840 high)	1.51

Hardwood or non-combustible setting blocks will be used to establish the correct edge cover

10. Recessed solid panels

All apertures to be factory prepared by a CERTIFIRE approved Licensed Door Processor No site cutting of apertures permitted as this will invalidate the certification.

Aperture dimensions: Doors may incorporate one or more recessed solid panels to the maximum sizes identified in the table below:

Area: Maximum total recessed solid panel area of 1.33 m² per leaf

Margins: 100 mm from the top and vertical edges, 200 mm to the bottom edge of the door leaf, 180 mm between solid recessed panel apertures.

Panel Specification: 44 mm thick Strebord blank recessed to a maximum depth of 10 mm both faces*, leaving a minimum thickness of 23 mm.

Recess faced with 3 mm MDF to both sides bonded with PVA adhesive.

Decorative timber beads are optional.

* Both faces must be recessed equally.

Maximum Permitted recessed solid panel Dimensions		
Max. Height (mm)	Max. Width (mm)	Max. Area (m ²)
1831 (at 728 wide)	728 (at 1831 high)	1.33

11. Intumescent Seals

CERTIFIRE certificated intumescent seals are required to be fitted to these doors as below.

For door assemblies to BS 476: Part 22 – classified as FD30

Mann McGowan Pyrostrip 100P intumescent Seals – See Table 1 for size restrictions

Doorset Configuration	Position	Intumescent Specification
Single-Acting, Single-Leaf Latched / Unlatched	Head	Single 10 mm wide by 4 mm thick – centrally positioned
	Vertical Edges	Single 10 mm wide by 4 mm thick – centrally positioned
Single-Acting, Double-Leaf Latched / Unlatched	Head	Single 10 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 10 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	Single 10 mm wide by 4 mm thick fitted centrally in the meeting edge of both leaves.

Lorient Type 617 or 100P intumescent Seals – See Tables 2 & 3 for size restrictions

Doorset Configuration	Position	Intumescent Specification
Single-Acting, Single-Leaf Latched / Unlatched	Head	Single 10 mm wide by 4 mm thick – centrally positioned
	Vertical Edges	Single 10 mm wide by 4 mm thick – centrally positioned
Single-Acting, Single-Leaf Latched / Unlatched	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Vertical Edges	Single 15 mm wide by 4 mm thick – centrally positioned
Single-Acting, Single-Leaf Latched Only	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Vertical Edges	Single 15 mm wide by 4 mm thick – centrally positioned
Single-Acting, Double-Leaf Latched / Unlatched	Head	Single 10 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 10 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	2No. 10 mm wide by 4 mm thick, positioned centrally, 12 mm apart, to primary leaf only
Single-Acting, Double-Leaf Unlatched Only. 12 mm equal rebated meeting stiles.	Head	Single 20 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 10 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	Single 15 mm wide by 4 mm thick fitted centrally in the meeting edge of both leaves.

Pyroplex FO8700 Graphite Rigid box intumescent Seals – See Table 4 for size restrictions

Doorset Configuration	Position	Intumescent Specification
Single-Acting, Single-Leaf Latched / Unlatched	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Vertical Edges	Single 15 mm wide by 4 mm thick – centrally positioned
Single-Acting, Double-Leaf Latched / Unlatched	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 15 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	Single 15 mm wide by 4 mm thick, positioned centrally, to the primary leaf only
Single-Acting, Double-Leaf Latched / Unlatched	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 15 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	2No. 10 mm wide by 4 mm thick, positioned centrally, 10 mm apart, to primary leaf only
Single-Acting, Double-Leaf Latched / Unlatched	Head	Single 15 mm wide by 4 mm thick – centrally positioned
	Hanging Edges	Single 15 mm wide by 4 mm thick – centrally positioned
	Meeting Edges	2No. 15 mm wide by 4 mm thick, positioned centrally, 10 mm apart, to primary leaf only

Latched or unlatched, single acting, single-leaves with maximum leaf dimensions 2040 mm high by 926 mm wide and of a minimum thickness of 44 mm may utilise alternative Intumescent in-line with the relevant CERTIFIRE approval for the proposed intumescent seal. All seals to be CERTIFIRE approved to Technical Schedule 35.

All other door assembly configurations should include the specific intumescent size type and location as specified within the data sheet (Tables 1, 2, 3 & 4).

Seals may be interrupted at hinge and latch positions. Seals may be fitted in the edge of the door or frame reveal.

Smoke seals may be included subject to the conditions contained within the relevant CERTIFIRE certificate for the smoke seal.

12. Hinges

Hinges shall be CE marked against EN 1935 for use on 30 minute timber fire door assemblies.

Number:	Minimum 3 No. hinges	
Type:	Steel lift off or butt hinges.	
Positions:*	Top Hinge:	Max 200 mm from the top of door to top hinge.
	Middle Hinge:	Middle hinge fitted centrally in the leaf height.
	Bottom.	Max 250 mm from the bottom of door to bottom hinge
Dimensions:	blade height:	100 mm (+3 mm / -2 mm)
	Blade width:	35 mm (+ 3 mm / - 4 mm)
	Thickness:	3 mm (+/- 1 mm)
	Knuckle dia.:	13.5 mm (+/- 1 mm)
Fixings:	Quantity:	3No. steel screws (minimum)
	Size:	No.5 by 30 mm long (minimum).
Intumescent Protection**	None required.	

* The datum in all cases is the centreline of the hinge.

** The hinge specification above overrides any requirement for additional intumescent identified in the hinge manufacturer's certification providing the hinge specification falls within the parameters identified in the table above, specifically maximum dimensions and material.

Any other CERTIFIRE approved hinge may be fitted, providing the hinge dimension are no greater than 10% in blade width and 25% in blade height from that approved in the table above (excluding the tolerances stated). Where the Certifire approved hinge exceeds the specification given in the table above, the minimum requirement for intumescent protection to the hinges, by-passing perimeter intumescent, and the material density and thickness for the door and frame elements given in the hinge manufacture's CERTIFIRE certificate shall apply.

13. Locks and Latches

Locks / latches where fitted shall be CE Marked in accordance with EN 1935 or EN179 for use on 30 minute timber fire doors.

Mortice type, automatic (sprung) latch bolt.

Max. case dimension:	166 mm high by 98 mm deep by 20 mm wide	
Max. forend dimension:	235 mm high by 25 mm wide	
Max. keep dimension:	185 mm high by 25 mm wide (excluding latch plate lip)	
Latchbolt material:	Steel or brass	
Position:	Max. 1100 mm from bottom of door to centreline of lockcase	
Cylinders	Euro profile single cylinder, double cylinder or cylinder / thumbturn CE marked in accordance with BS EN 1303 as suitable for use on FD30 fire resistant assemblies.	
Intumescent: protection*	Tubular latches	None required
	Lock / latch not exceeding: <ul style="list-style-type: none"> • 155 mm by 22 mm forend • 125 mm by 24 mm keep (excluding latch plate lip) 	1 mm Interdens Intumescent sheet material to keep only.

Intumescent: protection*	Lock / latch exceeding: <ul style="list-style-type: none"> • 155 mm by 22 mm forend • 125 mm by 24 mm keep (excluding latch plate lip) 	1 mm Interdens intumescent sheet material to fully warp the case and under the forend and keep.
	Doors fitted with a cylinder	1 mm Interdens intumescent sheet material to fully warp the case and under the forend and keep.

* The lock specification above overrides any requirement for additional intumescent identified in the lock manufacturer's certification providing the lock/latch specification falls within the parameters identified in the table above, specifically maximum dimensions and material.

Any other CERTIFIRE approved lock/latch may be fitted, providing no lock/strikeplate dimension is more than 25% of that approved in the table above and subject to the conditions contained within the relevant certificate. Where the Certifire approved lock/latch exceeds the specification given in the table above, the minimum requirement for intumescent protection to the locks, latches and strikeplates, by-passing perimeter intumescent, and the material density and thickness for the door and frame elements given in the lock/latch manufacture's CERTIFIRE certificate shall apply.

- Recessing for locks shall result in a tight fit, allowing for the intumescent protection specified.
- No restriction on type and material of face fixed mechanical lever handles and knobs providing these are wholly surface mounted (with the exception of the spindle and fixing holes) and the spindle hole is a maximum 15 mm in diameter.
- The Euro profile cylinder recess in the door face shall follow the shape of the cylinder and result in a tight fit.
- The use of oval profile cylinders is not permitted.
- Locks / latches are not permitted to be fitted to door leaves with rebated meeting stiles.

14. Self-Closing Devices

All doors are required to be fitted with a CERTIFIRE certificated self-closing device. The exceptions are doors kept locked shut such as service access doors. Note: closers with mechanical hold-open mechanisms are not permitted to be used. Building Regulations may identify locations within domestic locations where self-closing devices are not mandatory.

The closers shall have a power rating appropriate to the leaf sizes, subject to the closer having the ability to close the door from any angle and against any latch and/ or seals fitted. The closer shall have the ability to provide size 3 closing force. Where doors are unlatched a minimum size 3 shall be maintained.

Closers shall be CE Marked against EN 1154 and categorised as grade 1 – suitable for use on fire / smoke door assemblies.

14a Surface mounted overhead closers

Any CERTIFIRE approved surface mounted overhead closer may be fitted, subject to the conditions contained within the relevant certificate.

14b Transom Mounted Closers

Not permitted

14c Concealed Closers

Door assemblies may incorporate CERTIFIRE approved concealed overhead closers in accordance with the following:

- Concealed overhead closers are to be CERTIFIRE approved for use with single-acting, latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance of 30 minutes (code ITT).
- Minimum leaf thickness to be in accordance with the CERTIFIRE certificate of approval for the specified closer and CF807 (whichever is the greater thickness).
- Intumescent protection to the closer body and arm channel is to be in accordance with the CERTIFIRE certificate of approval for the specified closer.
- Closer body and arm positioning is to be in accordance with the CERTIFIRE certificate of approval for the specified closer.
- The minimum required frame density and section size are to be in accordance with the CERTIFIRE certificate of approval for the specified closer.
- Compliance is required with all additional requirements as stated within the CERTIFIRE certificate of approval for the specified closer.

14d Floor Springs

Not permitted

15. Ancillary items

Please note that hardware items other than those discussed within this certificate of approval are not permitted.

15a Protection plates and signage

Surface mounted plastic, steel, aluminium or brass plates are acceptable on the basis that:

- < 2mm thick
- Do not occupy more than 20% of the door leaf in total or exceed 500mm in height for kickplates and 300mm for mid-plates, whichever is the smaller.
- Do not wrap around the vertical edges, and on the closing face do not extend beneath the door stops (generally 40-50mm narrower than door width)
- Plates/signage can be bonded with a thermally softening adhesive. Additionally, screws may be used.

15b Flushbolts

Max. Dimension:	150 mm high x 25 mm deep x 19 mm wide
Material:	Steel.
Position:	Top and bottom on door edge.
Intumescent protection:	1 mm Interdens to base and sides of bolt body and under the keep.

Flushbolts are not permitted to be fitted in rebated meeting stiles.

15c Pull Handles

Screw-fixed, bolt-fixed from the back and back-to-back fixed pull handles of steel, brass, aluminium and nylon coated are permitted providing any through-bolt fixings are of steel and maximum bolt to bolt centres do not exceed 1000 mm.

A maximum 15 mm diameter recess is permitted for through bolt fixings.

Bolt through fixings will require intumescent protection in the form of a 1 mm thick graphite tube, or Intumescent paste to the full depth of the recess.

15d Air transfer grilles

No site cutting of apertures permitted as this will invalidate the certification.

Where apertures are pre-cut by a CERTIFIRE approved Licensed Door Processor, Intumescent Air Transfer Grilles may be fitted on site by NON-CERTIFIRE approved staff, however, the Intumescent Air Transfer Grilles shall be CERTIFIRE approved for use in FD30 timber based doors. The air transfer grilles must be fitted into apertures prepared in line with the relevant CERTIFIRE certificate for the air transfer grille. Care must be taken to ensure all fitting instructions are followed, including any constraints imposed by the CERTIFIRE certificate with regards to position of the air transfer grille within the door assembly.

15e Letter Plates

Where letter plates are fitted, the aperture for a letter plate may be formed on site by NON-CERTIFIRE approved staff, however, the letter plates shall be CERTIFIRE approved for use in FD30 timber based doors. The letter plates must be fitted into apertures prepared in line with the relevant CERTIFIRE certificate for the letter plate. Care must be taken to ensure all fitting instructions are followed, including any constraints imposed by the CERTIFIRE certificate with regards to position of the letter plate within the door assembly.

15f Dropseals

Door assemblies may incorporate CERTIFIRE approved dropseals with maximum dimensions of 35 mm high by 14 mm wide to the bottom edge of the door leaf.

Alternatively, door assemblies may be fitted with the following dropseals mortised into the bottom edge of the door leaf:

- Norsound NOR810s
- Lorient LAS8001si

Where dropseals are fitted the door leaf shall incorporate a 6 mm thick hardwood lipping to the bottom leaf edge. The hardwood lipping shall have a minimum density of 640 kg/m³.

Where dropseals are fitted, the recess for a dropseal may be formed on site by NON-CERTIFIRE approved staff. Care must be taken to ensure all fitting instructions are followed, including any constraints imposed by the CERTIFIRE certificate.

Note: Threshold gaps as stated within Section 3 of the Data Sheet are to be maintained between the bottom edge of the door leaf and the finished floor level.

15g Door Viewers

A Door viewer may be fitted into the leaf providing the viewer comprises a metal sleeve and an optical glass lens and is not positioned higher than 1450 mm from the bottom edge of the door leaf. The door viewer should have an external diameter of not greater than 14 mm and must be tightly fitted within the leaf. Intumescent protection is not required.

15h Coat Hooks and Other Surface Mounted Hardware

Ancillary items which are wholly surface mounted may be fitted providing:

- These items are screw fixed or bonded only
- Are not bolted through the full thickness of the door
- Are not directly above, or closer than 100 mm to any non-insulated glazing

15i. Electric Strikes / Electromechanical locks

Not permitted

16. Further Information

Further information regarding the details contained in this data sheet may be obtained from Falcon Panel Products Ltd (Tel: 01932 256580).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

CONSTRUCTIONAL SPECIFICATION FOR CERTIFIRE APPROVED CF 807

Introduction

This document specifies constructional and other details for Falcon FD30 doors manufactured from Strebord timber door blanks and certified by CERTIFIRE under certificate No. CF807. Only doors complying with the details of this document may be marked or marketed as CERTIFIRE approved. Any change to, or deviation from, this specification requires the agreement of CERTIFIRE.

General

CERTIFIRE approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will render the approval invalid and may jeopardise the fire performance of the product.

Scope of Approval

As defined in Certificate of Approval No. CF807.

1. Leaf and Overpanel Construction

1.1 Door leaf core: Material: Strebord 44 fine surface wood particleboard
 Thickness: 44 mm
 Density: 520 - 630 kg/m³

Or

 Material: Strebord 54 fine surface wood particleboard
 Thickness: 54 mm
 Density: 570 - 650 kg/m³

1.2 Internal framing: None required

1.3 Constructional facing: None required

1.4 Decorative finishes: Any timber veneer additional to above door leaf core / blank.
 Any non-metallic facing material, e.g., plastic laminate up to
 2 mm thick applied in addition to door leaf core / blank.

1.5 Moisture content: The moisture content of all timber based components shall
 be 9% ($\pm 2\%$)

2. Leaf Dimensions

2.1 Leaf thickness: 44 mm +10 mm / -1 mm (excluding finish)

2.2 Leaf height / width: As specified in Certificate of Approval

2.3 Configuration: As specified in Certificate of Approval

2.4 Meeting edges: Square or 12 mm equal rebates (20 mm lipping required)

3. Door Frame

3.1 To be as specified in Data Sheet

4. Overpanels / Sidepanels

- 4.1 Overpanels incorporating a transom rail 40 mm thick (minimum), may be included up to a maximum size of 1000 mm high.
- 4.2 Sidepanels incorporating a mullion rail 40 mm thick (minimum), may be included up to a maximum size of 1000 mm wide.
- 4.3 Flush overpanels may be included up to a maximum height of 600 mm
- 4.4 Overpanels / sidepanels to be manufactured as per door leaf specification, including lippings to all four edges and bedded against beads or the stop of the rebate and be screw fixed at minimum 400 mm centres.
- 4.5 Entire overpanel / side panel may be glazed in accordance with point 5 below.

5. Glazed Fanlights & Sidelights

- 5.1 Any CERTIFIRE approved glazing system may be used providing the installation details given in the appropriate certification documents are adhered to.

6. Glazed Apertures

- 6.1 One of more glazed openings systems may be included in each leaf.
- 6.2 Apertures Height: 2085 mm maximum (at 725 mm wide)
 Width: 822 mm maximum (at 1840 mm high)
 Area: Max. total glazed area per leaf of aperture size 1.51 m²
 Margins: No closer than 100 mm to the edge of the door leaf or
 between apertures.
- 6.3 Glazing system: As specified in Data Sheet

7. Recessed Solid Panels

- 7.1 One of more recessed solid panels may be included in each leaf.
- 7.2 Dimensions: Height: 1831 mm maximum (at 728 mm wide)
 Width: 728 mm maximum (at 1831 mm high)
 Area: Max. total glazed area per leaf of aperture size 1.33 m²
 Margins: No closer than 100 mm to the top and vertical edges,
 200 mm to the bottom edge of the door leaf and
 180 mm between panel apertures.
- 7.3 Panel specification: 44 mm thick Strebord blank recessed to a maximum
 depth of 10 mm both faces*, leaving a minimum
 thickness of 23 mm. Recess faced with 3 mm MDF to
 both sides bonded with PVA adhesive.
 Decorative timber beads are optional.
 * Both faces must be recessed equally.

8. Hardware/Intumescent Seals

As specified in Data Sheet

9. Labels

- 9.1 Labels of the CERTIFIRE design referencing CERTIFIRE CF807 and FD30 fire resistance, to be applied to each approved door leaf in the prescribed position